



Product Service

Attestation of Conformity

No. N8A 034521 0972 Rev. 04

Holder of Certificate: **Gree Electric Appliances, Inc. of Zhuhai**
West Jinji Rd., Qianshan
519070 Zhuhai, Guangdong
PEOPLE'S REPUBLIC OF CHINA

Product: **Split Air Conditioners**
(Split type air conditioner)

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 64111190577405

Date, 2020-09-28

(Sam Yang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 034521 0972 Rev. 04

Model(s):**Outdoor unit:**

GMV-VQ224WM/C-X, GMV-VQ280WM/C-X,
GMV-VQ335WM/C-X, GMV-VQ400WM/C-X,
GMV-VQ450WM/C-X, GMV-VQ504WM/C-X,
GMV-VQ560WM/C-X, GMV-VQ615WM/C-X;

mode exchange box:

NCHS1D, NCHS2D, NCHS4D, NCHS8D;

hydro box:

NRQR16L/A-T, NRQR30L/A-T

Brand:**GREE****Parameters:**

Rated Voltage/Frequency:	For outdoor unit: 380-415V, 3N~, 50/60Hz; for mode exchange box: 220-240V, 50/60Hz; for hydro box: 220-240V, 50Hz
Rated Power:	0,014kW for NCHS1D, 0,025kW for NCHS2D, 0,032kW for NCHS4D, 0,090kW for NCHS8D, 0,01kW for NRQR16L/A-T and NRQR30L/A-T
Rated Current:	23,0A for GMV-VQ224WM/C-X, 23,5A for GMV-VQ280WM/C-X, 24,1A for GMV-VQ335WM/C-X, 32,5A for GMV-VQ400WM/C-X, 39,3A for GMV-VQ450WM/C-X, 47,0A for GMV-VQ504WM/C-X, 48,0A for GMV-VQ560WM/C-X, 49,0A for GMV-VQ615WM/C-X
Protection Class:	Class I
Degree of Protection:	IPX4 for outdoor unit, IPX0B for hydro box, IPX0 for mode exchange box.
Refrigerant:	R410A

**Tested
according to:**

EN 60335-1:2012/A2:2019
EN 60335-2-40:2003/A13:2012
EN 62233:2008

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.