

**(air-to-air air conditioners)**

(\*) If  $C_{dc}$  is not determined by measurement then the default degradation coefficient air conditioners shall be 0,25. (\*\*)  
From 26 September 2018. Where information relates to multi-split air conditioners, the test result and performance data may be obtained on the basis of the performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.

**Information requirements  
(heat pump)**

|   |                           |       |                                   |   |              |        |                   |
|---|---------------------------|-------|-----------------------------------|---|--------------|--------|-------------------|
| Model(s):GMV-224WL/C-X  |                           |       |                                   |   |              |        |                   |
| Outdoor side heat exchanger of heat pump  | air                       |       |                                   |   |              |        |                   |
| Indoor side heat exchanger of heat pump   | air                       |       |                                   |   |              |        |                   |
| Indication if the heater is equipped with a supplementary heater  | no                        |       |                                   |   |              |        |                   |
| If applicable: driver of compressor   | electric motor            |       |                                   |   |              |        |                   |
| Parameters declared for   | Average climate condition |       |                                   |   |              |        |                   |
| Item  | symbol                    | value | unit                              | Item  | symbol       | value  | unit              |
| Rated heating capacity  | $P_{rated,h}$             | 22.40 | kW                                | Seasonal space heating energy efficiency  | $\eta_{s,h}$ | 167.8  | %                 |
| Declared heating capacity for part load at indoor temperature 20 °C and outdoor temperature $T_j$   |                           |       |                                   | Declared coefficient of performance for part load at given outdoor temperatures $T_j$ |              |        |                   |
| $T_j = -7\text{ °C}$  | $P_{dh}$                  | 14.15 | kW                                | $T_j = -7\text{ °C}$  | $COP_d$      | 2.70   | -                 |
| $T_j = +2\text{ °C}$  | $P_{dh}$                  | 8.50  | kW                                | $T_j = +2\text{ °C}$  | $COP_d$      | 3.70   | -                 |
| $T_j = +7\text{ °C}$  | $P_{dh}$                  | 5.54  | kW                                | $T_j = +7\text{ °C}$  | $COP_d$      | 6.80   | -                 |
| $T_j = +12\text{ °C}$   | $P_{dh}$                  | 3.50  | kW                                | $T_j = +12\text{ °C}$   | $COP_d$      | 9.60   | -                 |
| $T_{biv}$ = bivalent temperature  | $P_{dh}$                  | 14.15 | kW                                | $T_{biv}$ = bivalent temperature  | $COP_d$      | 2.70   | -                 |
| $T_{OL}$ = operation limit  | $P_{dh}$                  | 16.00 | kW                                | $T_{OL}$ = operation limit  | $COP_d$      | 2.47   | -                 |
| $T_j = -15\text{ °C}$ (if $TOL < -20\text{ °C}$ )   | $P_{dh}$                  | -     | kW                                | $T_j = -15\text{ °C}$ (if $TOL < -20\text{ °C}$ )                                     | $COP_d$      | -      | -                 |
| Bivalent temperature  | $T_{biv}$                 | -7.00 | °C                                | Operation limit temperature   | $T_{ol}$     | -10.00 | °C                |
| Degradation co-efficient heat pumps(**)   | $C_{dh}$                  | 0.25  | —                                 |   |              |        |                   |
| Power consumption in modes other than 'active mode'   |                           |       |                                   | Supplementary heater  |              |        |                   |
| Off mode  | $P_{OFF}$                 | 0.030 | kW                                | Back-up heating capacity (*)  | $el_{bu}$    | 0      | kW                |
| Thermostat-off mode   | $P_{TO}$                  | 0.082 | kW                                | Type of energy input  | Electric     |        |                   |
| Crankcase heater mode   | $P_{CK}$                  | 0.042 | kW                                | Standby mode  | $P_{SB}$     | 0.030  | kW                |
| Other items   |                           |       |                                   |   |              |        |                   |
| Capacity control  | variable                  |       |                                   | air flow rate, outdoor measured   | —            | 8000   | m <sup>3</sup> /h |
| Sound power level, indoor/outdoor measured  | $L_{WA}$                  | -/79  | dB                                |   |              |        |                   |
| Emissions of nitrogen oxides (if applicable)  | $NO_x(***)$               | -     | mg/kWh input GCV                  | Rated brine or water flow rate, outdoor side heat exchanger                           | —            | -      | m <sup>3</sup> /h |
| GWP of the refrigerant  | 2088                      |       | kg CO <sub>2</sub> eq (100 years) |   |              |        |                   |
| Contact details:<br>West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070   |                           |       |                                   | Name of manufacturer:<br>GREE ELECTRIC APPLIANCES,INC. OF ZHUHAI                      |              |        |                   |
| (*)<br>(**) If $C_{dh}$ is not determined by measurement then the default degradation coefficient of heat pumps shall be 0,25.<br>(***) From 26 September 2018.<br>Where information relates to multi-split heat pumps, the test result and performance data may be obtained on the basis of the performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer. |                           |       |                                   |   |              |        |                   |